



भारतीय रिजर्व बैंक-मुंबई क्षेत्रीय कार्यालय
संपदा कक्ष, बी के सी

Design, Supply, Installation, Testing and Commissioning of 9 Nos of Air Handling Units (AHUs) at RBI, BKC office, Bandra (E), Mumbai (Event no: RBI/Mumbai Regional Office/Estate/129/25-26/ET/743) – Minutes of Pre-bid Meeting

The pre-bid meeting for the captioned e-tender was held on January 19, 2026 (Monday) at 11:00 AM at Estate Cell, BKC.

2. Following Officers of Estate Cell, BKC attended the above pre-bid meeting-

S. No	Name	Designation
1	Shri. Abhijit S Warade	Assistant General Manager (Tech-Electrical)
2	Ms. Shweta Mhasvekar	Manager
3	Shri. Appasaheb Bhimrao Patil	Assistant Manager (Tech-Electrical)
4	Shri. K. Vishnu Vardhan	Assistant Manager

3. Following representatives from various firms were present in the meeting-

S. No	Name of Firm	Name of Representatives
1	M/s Snowmex Refrigeration	Shri. Vijay Bahadur Yadav
2	M/s Brite Industries	Shri. Khan Mohd Usman
		Shri. Shaikh Ayaz Ahmed
3	M/s AIRTEK HVAC LLP	Shri. Ammar Ansari
4	M/s Kailas Refrigeration Works	Shri. Parwej Akhtar Rahi
5	M/s Aria Climate Technic	Shri. Chetan Thakur
		Shri. Rohit Dalvi
6	M/s Sterling and Wilson Pvt Ltd.	Shri. Faiyaz Kausar

4. The queries, raised by the participants during the meeting and the clarification given by the Bank are given below:

S No	Query raised by the firms	Comments/Clarification given by the Bank
1	Make and Thickness of 'C' Class chilled water pipe	It was clarified that the bidders may refer Item Sr. No. 3 of BOQ of tender document. Further, it was clarified that the approved make for 'C' Class chilled water pipe is Tata/Jindal/SAIL. Thickness of chilled water pipe shall be minimum 4.5 mm.

5. All terms and conditions of the tender shall remain unchanged.

**Regional Director
Maharashtra**