



बेटी बचाओ
बेटी पढ़ाओ

Reserve Bank of India / भारतीय रिज़र्व बैंक
Nagpur / नागपुर
Estate Department / संपदा विभाग

Design, Supply, Installation, Testing and Commissioning of FM 200/NOVEC 1230/Equivalent Fire Suppression System for the LT Panel at substation of Bank's Office Building at RBI, Nagpur – Minutes of the Pre-bid meeting

The pre-bid meeting for the [captioned work](#) was conducted by Estate Department, at Conference Hall, Main Office Building on **October 01, 2025** at **11:00 AM** in presence of the following:

For Reserve Bank of India:

1. B Kamal Nayak, Assistant General Manager (Estate)
2. R K Khandelwal, Assistant Manager (Tech-Electrical)
3. Palash Chaurasia, Assistant Manager (Estate)
4. Ishan Jamjare, Assistant (Estate)

Tenderers:

1. Vaibhav Hingave from M/s Security Engineers Pvt Ltd

Gist of the queries raised by the prospective bidders and Bank's clarification on the same is as follows:

Query: Which fire suppression agent can be used as a substitution so that our bid aligns with tender requirements while adhering to sustainability and operational best practices?

Clarification: Fire suppression agent should be FM 200/ Novec 1230/ **equivalent** (NFPA 2001 edition approved and UL approved clean agent) as per technical specifications under section VI (Page No. 83) of the tender.