

## Providing, fabrication and fixing structural steel and metal related works including railing work for CENTRE FOR ADVANCED FINANCIAL RESEARCH AND LEARNING (CAFRAL)-Pre-bid Minutes of Meeting

Estate Office, Mumbai Regional Office, Reserve Bank of India had invited limited e-tender was invited for the <u>captioned work</u> on July 05, 2024 and as per SOT, prebid meeting was conducted at 03.00 PM on July 10, 2024

(a) Bank's officials who have attended the meeting:

| SI | Name                  | Designation                    |
|----|-----------------------|--------------------------------|
| 1. | Shri Nayan K Khadia   | DGM (Tech.) E-I-C              |
| 2. | Shri Sanjeev Jain     | Manager (Tech-Civil)           |
| 3. | Shri Manoj Dachepally | Assistant Manager (Tech-Elect) |

(b) Representatives of intending firms who have attended the meeting:

| SI | Name                | Name of the Firm          |
|----|---------------------|---------------------------|
| 1  | Smt Monalisa Joseph | M/s R K Interior Projects |
|    | Shri Ruparam Kaswar |                           |
|    | Shri Vijay Sawant   |                           |
|    | Shri Hardev Ram Rao |                           |

(c) Queries raised by the prospective bidders and the clarifications given by the Bank's officials are as follows:

| Item<br>No | Existing Specifications  | Revised  |
|------------|--|--|
| 1 (i)      | Providing and fixing stainless steel (Grade 316) railing fabricated in shape and size as | Providing and fixing stainless steel ( <b>Grade 304)</b> railing fabricated in shape |



|   | shown in the drawing and made of Hollow tubes   | and size as shown in the drawing and made of Hollow tubes |
|---|---|---|
| 3 | Mode of measurement: The payment shall be made on the weight of the structural member already provided at the site. | Mode of measurement: As per relevant IS code              |

## Enclosure:

- 1. Indicative Stainless steel balcony railing drawing No.-01.
- 2. Indicative Stainless steel staircase railing drawing No.-02