



भारतसरकार
केन्द्रीय लोकनिर्माणविभाग
कार्यालय कार्यपालक अभियंता-1 (सिविल)



निर्माणसदन, कमरानं. 02, 52-ए अरेराहिल्स, भोपाल 462011

Ph. : 0755-2679322, Fax : 2559506 E-mail : eebcd1cpwd-mp@nic.in&eebcd1cpwd786@yahoo.com

पत्र क्र: 23(758)/का.अ.-1/भोपाल/2025-26/447-A -

भोपालदिनांक : 34/02/2026

//CORRIGENDUM-1//

Name of work :-C/o Additional Quarters for Staff/Officers of Reserve Bank of India at Char Imli, Bhopal, Madhya Pradesh in EPC Mode-III.

SH:-C/o 72 Nos. Grade A Qtrs. (Stilt + 9), 10 Nos. Grade D&E & 1 No. Grade F Qtrs. (Stilt + 7), 1 No. R&D Bungalow (G+1), 28 Nos. Class-III Qtrs. (Stilt + 7), Facility block (G+4) , Swimming Pool,33KV Electrical Sub-station & Building, 2Nos Gate &Security Blocks including Internal & External Water supply, Sanitary Installation, Electrical installation and development Works & bulk services of Roads, Footpath, Drains, retaining walls, UG Sump & pump room, Sewage Treatment Plant(STP), upgradation of main Campus Boundary Wall, CCTV System, Networking, DG Set, Fire Fighting System, Fire Alarm System, Street Lighting, Lifts, EV Charging, OWC, Domestic & Flushing Water pumping System, Solar PV System, Boom Barrier, Gas Suppression System, Signage's, UPS, Mechanical Ventilation and Pressurization System, BMS, Horticulture work ,site office, barricading construction sites including demolishing of existing residential D block and temporary structures.(Package-1).

NIT No. : 66/CE(Bhopal)/EE-I/2025-26.

The pre-bid meeting held on 19.02.2026 at 3.00 pm in the conference hall of O/o Chief Engineer (Bhopal), CPWD, Nirman Sadan, Bhopal for the aforesaid work.

During the pre-bid meeting, various issues and observations were clarified. These were discussed in detail, and after thorough deliberation, the following decisions were made. Accordingly following corrigendum is issued to the NIT No. 66/CE(Bhopal)/EE-I/2025-26.

Sl no	NIT Page no	Existing Provision in NIT	Modified/Amendment in NIT
1	Page no 927	No Provision in NIT	Finished ground level shall be kept minus (-) 150mm with respect to top finished level of road.
2	Page no967 &968	No Provision in NIT	Following structural Drawings are attached in NIT, have already been submitted to MANIT Bhopal for vetting, after receipt of vetted structural drawings of the following works shall be issued for construction and on account of any changes or minor correction in the structural drawing, nothing shall be paid extra. <ul style="list-style-type: none"> 1. Site office. 2. Main Gate with wicket gate and Canopy at entry& exit 3. Balancing Tank of swimming pool. 4. Shed for STP and OWC. 5. Shed for Grade D block at 6th Floor
3	Page no 752	No Provision in NIT	EV charger shall not be accepted below 7.00 KW. However if higher capacity of EV charger is provide by the agency, then it shall be acceptable without paying of extra cost.

Contd...2

All other terms and conditions of the NIT will remain unchanged. This corrigendum shall form part of the agreement.

This issues with the approval of CE (Bhopal), CPWD, Bhopal.


कार्यपालक अभियन्ता-1
केन्द्रीय लो.नि.वि, भोपाल